

HEALTH REGULATION AND LICENSING ADMINISTRATION
DIVISION OF COMMUNITY HYGIENE
community.hygiene@dc.gov

ITEMS CHECKED DURING A SWIMMING POOL INSPECTION

Personnel

1. Licensed Pool Operator on duty
2. Qualified Lifeguard on duty

Records

3. Records adequate and current
4. Reporting Illness, Accidents

Postings

5. Appropriate warnings and prohibitions
6. Emergency phone numbers
7. Admission rules, signs, and postings
8. Licenses and permits

Safety Equipment

9. Ring buoy with adequate rope
10. Shepherd's hook with 16-foot pole
11. Backboard, cots, and emergency blankets
12. First aid supplies and safety equipment (AEDs; pathogen control kit) provided
13. Elevated lifeguard platform or chairs
14. First aid and safety equipment properly located
15. Emergency care area: telephone accessibility and use

Bathhouse

16. Floors: clean, in good repair
17. Walls & ceilings: clean, in good repair
18. Adequate lighting and ventilation
19. Plumbing: no leaks, water temperature, flow, and prohibition
20. Plumbing: no cross-connections
21. Plumbing fixtures: clean, in good repair
22. Plumbing fixtures: Adequate toilets, urinals, hand basins and showers
23. Dressing and Sanitary Facilities: cleanability, materials, and accommodations
24. Adequate supplies: Soap & soap dispensers, toilet tissue, receptacles (showers & sinks)

Deck & Pool

25. Lighting: approved wiring and GFCI protection
26. Adequate lighting
27. Diving equipment: properly secured
28. Rails, ladders, steps, and guard chairs: properly secured
29. Depth markings: plainly marked, appropriately located
30. Drinking fountain: provided and in good repair

In addition, the following items will be check:

- Clarity and pH
- Deep and Shallow end free Chlorine residual
- Flow Meter Reading (gpm)
- Total alkalinity

Deck & Pool (con't)

31. Decks & walkways: sufficient width, good repair, clean, properly drained, impervious and with a slip-resistant surface
32. Pool side & bottom: clean, good repair no algae
33. Bathing load: safety standards observed
34. Fencing & gates: properly constructed, in good repair, sufficient height, appropriate latches & locks
35. Spectators: excluded from deck and pool area
36. Food & beverage: excluded from deck and pool area

Premises

37. Drainage: wastewater, no standing water, or muddy areas
38. Garbage receptacles: sufficient number, location, and closable
39. Equipment rooms: security access, ventilation, and floor coverings
40. Facility maintenance: equipment and eye wash station

Water Treatment & Equipment

41. Water level: continuous skimming action
42. Skimmers: weirs present and functioning, basket in place
43. Scum gutter: clean and free flowing
44. Filter room: lean, adequate lighting, and dry
45. Circulation systems: no cross connections
46. Circulation systems: hair & lint entrapment devices
47. Circulation systems: grates over and pool drains, and suction fittings
48. Filters & pumps: good repair, valves and gauges functioning and labeled
49. Disinfectant & chemical feeders: disinfectant and other chemical feeder in good repair and operating
50. Vacuum cleaning equipment: present, in good repair
51. Chemicals: properly stored, properly used, sufficient quantity on hand
52. Test kits required for pH, disinfectant, and other chemicals in use
53. Water Quality, Source, & Temperature
54. Controlling pests

- Pressure Gauge Readings:
- both Influent (psi) and Effluent (psi)
- Cyanuric acid concentration
- Temperature

